



**MCPS RADON TESTING – EXECUTIVE SUMMARY**

Site Name	Rollingwood Center (Rochambeau, The French International School)
Date of Test Report	01/20/2022
Round of Testing	Initial Follow-up Post Remediation 2 Year Testing <u>5 Year Testing</u> HVAC Upgrade Window Replacement New Addition New Facility
# Rooms Tested	17
# Rooms $\geq$ 4.0 pCi/L	0
Lowest Value	<0.3 pCi/L
Highest Value	1.7 pCi/L

**Project Status**

Current Project Status at this time: Testing Complete; no further action.



January 20, 2022

Mr. Richard Cox  
Indoor Air Quality Team Leader  
Montgomery County Public Schools  
Gaithersburg, MD 20879

Re: **Radon Testing Services**  
KCI Job # 122108316

Location: Rollingwood Center (Rochambeau, The French International School)  
3200 Woodbine St.  
Chevy Chase, MD 20815

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for Rollingwood Center (Rochambeau, The French International School) located at 3200 Woodbine St. Chevy Chase, MD 20815 (subject site).

**Scope of Services:**

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Proficiency Program (NRPP) Radon Measurement Specialist (certification #111004 RT) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from <https://www.montgomeryschoolsmd.org> or [www.epa.gov/radon](http://www.epa.gov/radon).

KCI visited the site on December 13, 2021 and deployed nineteen (19) activated charcoal (AC) radon test kits. KCI deployed radon test kits in all frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance.

A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI also included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on December 16, 2021 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc. is a NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936 Butler Bridge Road, Mills River, North Carolina.

### **Evaluation of Testing Conditions:**

These tests represent:

- Follow-up to initial testing.

These tests were conducted to:

- Evaluate radon concentrations at the facility.

According to AARST, *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*, ideal testing conditions would be when the building is fully occupied and the heating system is active. For this test, the facility's HVAC system was operating in heating mode; therefore, KCI concludes that this test was conducted during ideal testing conditions.

KCI recorded observations of the following conditions in each room during the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

KCI also compiled weather data for the testing period and conducted observations of relevant field conditions. During the test period, weather records indicate low temperatures were in the low 30°Fs and high temperatures ranged from the mid 50°Fs to the high 60°Fs. Maximum sustained winds ranged from 3-12 miles per hour. Average humidity was around 50% with 0.0 inches of precipitation (rain) was recorded during testing period.

### **Results:**

The sampling locations and analytical results are listed on Table 1 (Attachment B). The quality control sample locations and analytical results are listed on Table 2 (Attachment B). Sampling locations and associated test kit identification numbers and relevant field observations are listed on Table 3 (Attachment B). The laboratory analytical results are included in Attachment C. Laboratory results and exposure data for the spike samples are also included in Attachment C.

The results of the radon test analysis indicated the following:

<b>Radon Concentration</b>	<b>Room</b>	<b>Result</b>
<b>≥4.0 pCi/L</b>	NA	NA
<b>&lt;4.0 pCi/L</b>	See Attachment B	

<b>Quality Control Samples</b>	
Results of Blank Canisters:	The office blanks, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L.
Adequate Laboratory Precision?	Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved.
Spike Sample Analysis:	The Spike Sample analysis results indicate the laboratory is operating within statistical control limits.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 891-1769.

Sincerely,



Tyler P. McCleaf  
Radon Measurement Provider  
#111004 RT  
KCI Technologies, Inc.

Attachments:     A- Floor Plan with Test Locations  
                      B- Table 1-3, Radon Test Summary Spreadsheets  
                      C- Laboratory Analytical Results

# ATTACHMENT A

## Floor Plan With Test Locations

# ATTACHMENT B

## Radon Test Summary Spreadsheets

**Table Notes:**

AC- Activated Charcoal

ACI- Air Check, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

OC- Quality Control

Table 1- Radon Testing Results		
Rollingwood Center		
Test Period: 12/13/2021-12/16/2021		
Kit Number	Room / Area	Result
9339931	105	1.2
9341751	102	0.6
9341758	209	1.1
9341761	103	0.7
9341785	GYM	1.3
9341787	SECRETARY	1.1
9341798	211	1.1
9346981	213	1
9346984	100	0.8
9348322	WORKROOM	1.7
9348345	207	1.4
9348346	104	0.5
9348350	211	1.2
9348354	GYM	< 0.3
9348367	215	0.9
9348378	OFFICE	1.3
9348382	GYM	1.4
9348383	DIRECTOR OFFICE	1.2
9348386	210	0.7



Table 2- Radon Testing Results			
Rollingwood Center			
Test Period: 12/13/2021-12/16/2021			
Kit Number	QC Type	Room / Area	Result
9348350	D	211	1.2
9348354	FB	Gym	< 0.3
9347000	OB	OFFICE BLANK	< 0.3
9347992	TB	TRAVEL BLANK	< 0.3



# ATTACHMENT C

## Laboratory Analytical Results

Radon test result report for:  
**ROLLINGWOOD  
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9346984	100	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.8 ± 0.3	2021-12-17
9341751	102	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.6 ± 0.3	2021-12-17
9341761	103	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.7 ± 0.3	2021-12-17
9348346	104	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.5 ± 0.3	2021-12-17
9339931	105	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.2 ± 0.3	2021-12-17
9348345	207	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.4 ± 0.3	2021-12-17
9341758	209	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.1 ± 0.3	2021-12-17
9341798	211	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.1 ± 0.3	2021-12-17
9348350	211	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.2 ± 0.3	2021-12-17
9346981	213	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.0 ± 0.3	2021-12-17
9348367	215	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.9 ± 0.3	2021-12-17
9348386	210	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	0.7 ± 0.3	2021-12-17
9348383	DIRECTOR OFFICE	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.2 ± 0.3	2021-12-17
9348354	GYM	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	< 0.3	2021-12-17
9348382	GYM	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.4 ± 0.3	2021-12-17
9341785	GYM	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.3 ± 0.3	2021-12-17
9348378	OFFICE	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.3 ± 0.3	2021-12-17
9341787	SECRETARY	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.1 ± 0.3	2021-12-17
9348322	WORKROOM	2021-12-13 @ 11:00 am	2021-12-16 @ 9:00 am	1.7 ± 0.3	2021-12-17

**EXPOSURE IN BOWSER-MORNER RADON CHAMBER**

CLIENT KCI Technologies, Inc. Job Number 203404

NOMINAL Conditions: Radon Conc 16.2 pCi/L Rel. Hum 28.8 % Temp. 59.9 F

Date Start: 12/24/21 Date Stop: 12/27/21 Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: 0809 Time Stop: 0809 Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: (2) Char Bags- Device No.'s: \_\_\_\_\_

9341721, 9341722

G4 left

Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_ Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: \_\_\_\_\_ Device No.'s: \_\_\_\_\_

Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_ Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: \_\_\_\_\_ Device No.'s: \_\_\_\_\_

**Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)  
Background = 7  $\mu$ R/h Elevation = 820 ft**



### Radon Test Kit Chain of Custody

Project Name: MCPS Radon - December 2021 Schools

Name of Schools:

1. 45 Gude
2. Concord Center
3. English Manor
4. Smith Education Center
5. Randolph Main. & Tran.
6. Rollingwood Center
7. Ewing at Plum Orchard

---

	Date	Initials
Radon Test Kits Deployed	12/13/2021	JM
Radon Test Kits Collected	12/16/2021	JM
Radon Test Kits Shipped to Lab*	12/16/2021	JM
Radon Test Kits Received by Lab*	12/17/2021	JM

\*All samples sent to Air Check, Inc., 1936 Butler Bridge Rd, Mills River, NC 28759

---

December 31, 2021

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**SK**  
**MA** MCPS - Spike Sample Lab Results. Measured values are satisfactory, i.e., within  $\pm 25\%$  of the chamber's reference value (16.2 pCi/L).

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9341721	1	2021-12-24 @ 8:00 am	2021-12-27 @ 8:00 am	11.6 $\pm$ 0.9	2021-12-31
9341722	1	2021-12-24 @ 8:00 am	2021-12-27 @ 8:00 am	15.4 $\pm$ 1.2	2021-12-31

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498