



MCPS RADON TESTING

Executive Summary: Fairland Elementary School

Date of Test Report:	1/13/2016
Round of Testing:	Initial Follow-up Post Remediation
# Rooms Tested:	68
# Rooms \geq 4.0 pCi/L:	0
Low Value:	< 0.3
High Value:	2.7

Project Status:

Initial testing completed; One test kit was missing from Storage 1; however, based on the low test results from adjacent rooms and within the school, no further action is recommended at this time.



January 13, 2016

Mr. Richard Cox
Indoor Air Quality Team Leader
Montgomery County Public Schools
850 Hungerford Drive
Rockville, MD 20850

Re: **Radon Testing Services**
KCI Job # 12146341.20

Location: Fairland Elementary School
14315 Fairdale Road
Silver Spring, MD 20905

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the Fairland Elementary School, located at 14315 Fairdale Road in Silver Spring, Maryland 20905 (subject site).

Scope of Services:

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Safety Board (NRSB) Radon Measurement Specialist (certification #14SS056) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from www.montgomerycountymd.gov/dep/air/radon or www.epa.gov/radon.

KCI visited the site on December 21, 2015 and deployed seventy-four (74) activated charcoal (AC) radon test kits. KCI deployed radon test kits in all frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance. A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI also included 4 duplicate samples (10%), 1 field blanks (3%), and 1 office blank (1%). Prior to sampling, KCI returned 1% of the test batch to the laboratory for analysis as lab transit blanks. In addition, KCI submitted six (6) test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on December 24, 2015 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc.

is a NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936 Butler Bridge Road, Mills River, North Carolina.

Evaluation of Testing Conditions:

The operating condition that represents the greatest amount of significantly occupied time for this building is; heating active, with outdoor temperature averages $\leq 65^{\circ}$ F.

KCI concludes that the test period reasonably represents normal conditions when the building is significantly occupied. Clear characterization of the radon hazard is most likely to be observed under this normal operating condition. Based on the evaluation of test conditions, this test should reasonably characterize radon hazards.

KCI also conducted observations of field conditions which could affect the results of the test and compiled weather data for the testing period. KCI recorded observations of the following conditions in each room during the deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

Results:

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥ 4.0 pCi/L	None	n/a
< 4.0 pCi/L	See Attachment B	

Notes:

D- Duplicate sample

All field blanks, office blanks, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L. Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved. The Spike sample analysis results indicate the laboratory is operating within statistical control limits.

The sampling locations, field observations, and analytical results are listed on Table 1 (Attachment B). The laboratory analytical results are also attached (Attachment C). Laboratory results and exposure data for the spike samples are also included in Attachment C.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 316-7800.

Sincerely,



James M. Mouldale
Radon Measurement Specialist
KCI Technologies, Inc.

Attachments: A- Floor Plan with Test Locations
 B- Table 1-Radon Test Summary Spreadsheet
 C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Chek, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

QC- Quality Control

Radon Testing Results		
Fairland Elementary School		
Test Period: 12/21/15-12/24/15		
Kit Number	Room / Area	Result
7713632	1	2.3
7713649	2	1.2
7713651	3	0.7
7713650	4	0.9
7713652	5	1
7713656	6	0.7
7713655	7	0.8
7713625	8	< 0.3
7713624	10	0.7
7713623	11	< 0.3
7713621	12	0.9
7713622	13	1.1
7713635	14	< 0.3
7713637	15	0.9
7713639	16	< 0.3
7713628	17	0.6
7713633	18	1
7713646	19	0.6
7713643	20	1.4
7713641	21	1.9
7713642	21	2.1
7713640	22	1.9
7713678	34	0.7
7713608	101	1.1
7713611	102	1.1
7713612	102	< 0.3
7713674	103	1
7713605	104	1.2
7713613	105	0.9
7713615	106	0.6
7713618	106	0.8
7713675	107	1.2
7713606	108	1.6
7713616	108	0.9
7713617	109	0.9
7713619	110	0.6
7713610	111	0.8
7713677	208	0.8
7713676	209	0.9
7713634	16A	0.7
7713638	16B	0.7
7713662	ASSIST PRINCIP	0.8
7713679	BLDG SER 2	1.8
7713631	BLDG SERV 1	0.5
7713669	CAFE	1
7713670	CAFE	1.2

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
Fairland Elementary School		
Test Period: 12/21/15-12/24/15		
Kit Number	Room / Area	Result
7713664	CONFERENCE	2.1
7713665	COPY ROOM	0.8
7713645	GYM	1
7713647	GYM	< 0.3
7713648	GYM	1.3
7713653	GYM	1
7713672	GYM OFFICE	1.2
7713654	HEALTH	1.1
7713667	KITCHEN	1.2
7713630	MAT PREP	0.6
7713626	MAT PREP STORAGE	1.3
7713627	MEDIA CNTR	0.5
7713629	MEDIA CNTR	0.8
7713671	OBSERVATION RM	0.8
7713658	OFFICE	< 0.3
7713663	PRINCIPAL	2.7
7713659	PRIVATE	0.8
7713620	STORAGE 2	0.8
7713636	STORAGE 3	1.1
7713614	* STORAGE1 (missing)	-
7713661	TELE 2	0.9
7713644	TELE RM 1	1.3

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
Fairland Elementary School		
Test Period: 12/21/15-12/24/15		
Kit Number	QC Type	Result
7713668	D (CAFE)	1
7713673	D (GYM OFFICE)	1.1
7713666	D (KITCHEN)	0.8
7713657	D (OFFICE)	0.8
7713660	FB (HEALTH)	< 0.3
7707336	OB (0)	< 0.3

Table Note:

* Missing or Compromised Sample

ATTACHMENT C

Laboratory Analytical Results

Radon test result report for:

FAIRLAND ES

1

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7707336	0	2015-12-21 @ 3:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-28
7713632	1	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	2.3 ± 0.4	2015-12-28
7713624	10	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.7 ± 0.3	2015-12-28
7713608	101	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.1 ± 0.3	2015-12-28
7713611	102	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.1 ± 0.3	2015-12-28
7713612	102	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	< 0.3	2015-12-28
7713674	103	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	1.0 ± 0.3	2015-12-29
7713605	104	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.2 ± 0.3	2015-12-28
7713613	105	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.9 ± 0.3	2015-12-28
7713615	106	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.6 ± 0.3	2015-12-29
7713618	106	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.4	2015-12-29
7713675	107	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	1.2 ± 0.3	2015-12-28
7713606	108	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.6 ± 0.3	2015-12-28
7713616	108	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.9 ± 0.3	2015-12-28
7713617	109	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.9 ± 0.3	2015-12-28
7713623	11	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	< 0.3	2015-12-28
7713619	110	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.6 ± 0.3	2015-12-28
7713610	111	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.3	2015-12-28
7713621	12	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.9 ± 0.3	2015-12-28
7713622	13	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.1 ± 0.3	2015-12-28
7713635	14	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-28
7713637	15	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.9 ± 0.3	2015-12-28
7713639	16	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-28
7713634	16A	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.7 ± 0.3	2015-12-28
7713638	16B	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.7 ± 0.3	2015-12-29
7713628	17	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.6 ± 0.3	2015-12-28
7713633	18	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.0 ± 0.3	2015-12-28
7713646	19	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.6 ± 0.3	2015-12-28
7713649	2	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	1.2 ± 0.3	2015-12-28
7713643	20	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.4 ± 0.3	2015-12-28
7713677	208	2015-12-21 @ 2:00 pm	2015-12-24 @ 9:00 am	0.8 ± 0.3	2015-12-28
7713676	209	2015-12-21 @ 2:00 pm	2015-12-24 @ 9:00 am	0.9 ± 0.3	2015-12-28
7713641	21	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.9 ± 0.4	2015-12-28
7713642	21	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	2.1 ± 0.4	2015-12-28
7713640	22	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.9 ± 0.3	2015-12-28
7713651	3	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	0.7 ± 0.3	2015-12-28
7713678	34	2015-12-21 @ 2:00 pm	2015-12-24 @ 9:00 am	0.7 ± 0.3	2015-12-28

January 12, 2016 **LABORATORY ANALYSIS REPORT ****

Radon test result report for:

FAIRLAND ES

1

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7713650	4	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	0.9 ± 0.3	2015-12-28
7713652	5	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	1.0 ± 0.3	2015-12-28
7713656	6	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	0.7 ± 0.3	2015-12-28
7713655	7	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.3	2015-12-29
7713625	8	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	< 0.3	2015-12-28
7713662	ASSIST PRINCIP	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.8 ± 0.3	2015-12-28
7713679	BLDG SER 2	2015-12-21 @ 2:00 pm	2015-12-24 @ 9:00 am	1.8 ± 0.3	2015-12-28
7713631	BLDG SERV 1	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.5 ± 0.3	2015-12-28
7713668	CAFE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.0 ± 0.3	2015-12-28
7713670	CAFE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.2 ± 0.3	2015-12-28
7713669	CAFE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.0 ± 0.4	2015-12-29
7713664	CONFRENCE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	2.1 ± 0.4	2015-12-28
7713665	COPY ROOM	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.8 ± 0.4	2015-12-29
7713645	GYM	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.0 ± 0.3	2015-12-28
7713647	GYM	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-28
7713648	GYM	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.3 ± 0.3	2015-12-28
7713653	GYM	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.0 ± 0.3	2015-12-28
7713672	GYM OFFICE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.2 ± 0.3	2015-12-28
7713673	GYM OFFICE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.1 ± 0.3	2015-12-28
7713654	HEALTH	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.1 ± 0.3	2015-12-28
7713660	HEALTH	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-28
7713666	KITCHEN	2015-12-21 @ 1:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.3	2015-12-28
7713667	KITCHEN	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.2 ± 0.3	2015-12-28
7713630	MAT PREP	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.6 ± 0.3	2015-12-29
7713626	MAT PREP STORAGE	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	1.3 ± 0.4	2015-12-28
7713627	MEDIA CNTR	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.5 ± 0.3	2015-12-28
7713629	MEDIA CNTR	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.4	2015-12-29
7713671	OBSERVATION RM	2015-12-21 @ 2:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.3	2015-12-28
7713657	OFFICE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.8 ± 0.3	2015-12-28
7713658	OFFICE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	< 0.3	2015-12-29
7713663	PRINCIPAL	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	2.7 ± 0.5	2015-12-29
7713659	PRIVATE	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.8 ± 0.3	2015-12-28
7713620	STORAGE 2	2015-12-21 @ 12:00 pm	2015-12-24 @ 8:00 am	0.8 ± 0.3	2015-12-28
7713636	STORAGE 3	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.1 ± 0.4	2015-12-29
7713614	STORAGE1	@	@		
7713661	TELE 2	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	0.9 ± 0.4	2015-12-29
7713644	TELE RM 1	2015-12-21 @ 1:00 pm	2015-12-24 @ 9:00 am	1.3 ± 0.3	2015-12-28

December
29,
2015

****LABORATORY ANALYSIS
REPORT****

Radon test result report for:
TRANSIT DEC 14 2015
NONE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7704395	TRANSIT 1	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706508	TRANSIT 10	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706510	TRANSIT 11	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706511	TRANSIT 12	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706505	TRANSIT 13	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704371	TRANSIT 14	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706506	TRANSIT 15	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704381	TRANSIT 16	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704399	TRANSIT 17	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704390	TRANSIT 18	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704396	TRANSIT 2	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704364	TRANSIT 3	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704370	TRANSIT 4	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7704368	TRANSIT 5	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706524	TRANSIT 6	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706526	TRANSIT 7	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706518	TRANSIT 8	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16
7706516	TRANSIT 9	2015-12-13 @ 10:00 am	2015-12-15 @ 10:00 am	< 0.3	2015-12-16

December
23,
2015

**LABORATORY ANALYSIS
REPORT ****

Spike Sample Laboratory Results

Radon test result report for:
MCPS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7706380	101	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	25.2	2015-12-23
7706381	102	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.5	2015-12-23
7706208	103	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	27.7	2015-12-23
7705132	104	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	28.6	2015-12-23
7706366	105	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.5	2015-12-23
7706211	106	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.1	2015-12-23

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Note: Spike samples are test canisters that are deliberately exposed to a controlled high level of radon in a laboratory. They provide a quality control measure in the testing process and do NOT reflect radon levels in the building being tested.

EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCI Technologies Inc. Job Number 173224

NOMINAL Conditions: Radon Conc 26.9 pCi/L Rel. Hum 49.6 % Temp. 69.9 F

Date Start: 12/18/15 Date Stop: 12/21/15 Date Start: _____ Date Stop: _____

Time Start: 0929 Time Stop: 0929 Time Start: _____ Time Stop: _____

Device No.'s: 7705132, 7706208, Device No.'s: _____

7706211, 7706366, _____

7706380, 7706381 _____

F3 Left

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

**Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)
Background = 7 μ R/h Elevation = 820 ft**



Chain of Custody

Project Name: MCPS Radon Phase II

School Names:

- | | | |
|---------------------------|-----------------------------|---------------------------|
| 1. Bannockburn ES | 11. Sherwood HS | 21. Fairland ES |
| 2. Walt Whitman HS | 12. Hadley Farms | 22. Cannon Road ES |
| 3. Walter Johnson HS | 13. S. Christa McAuliffe ES | 23. Richard Montgomery HS |
| 4. North Chevy Chase ES | 14. Ronald A. McNair ES | 24. Brooke Grove ES |
| 5. Piney Branch ES | 15. MLK MS | 25. Belmont ES |
| 6. Forest Knolls ES | 16. Ashburton ES | 26. Emory Grove |
| 7. Newport Mill MS | 17. Bradley Hills ES | 27. Clarksburg HS |
| 8. Broad Acres ES | 18. Flora M. Singer ES | 28. Clarksburg ES |
| 9. Briggs Chaney MS | 19. Woodlin ES | 29. John T. Baker MS |
| 10. Blair G. Ewing Center | 20. Montgomery Knolls ES | |

	Date	Initials
Radon Test Kits Deployed	12/21/2015	JM
Radon Test Kits Collected	12/24/2015	JM
Radon Test Kits Shipped to Lab*	12/24/2015	JM
Radon Test Kits Received by Lab*	12/28/2015	JM

*All samples sent to Air Check, Inc., 1936 Butler Bridge Road, Mills River, NC 28758