



MCPS RADON TESTING

Executive Summary: William Tyler Page Elementary School

Date of Test Report:	2/17/2016 (Rev 1)
Round of Testing:	Initial Follow-up Post Remediation
# Rooms Tested:	47
# Rooms \geq 4.0 pCi/L:	0
Low Value:	< 0.3
High Value:	3.2

Project Status:

Initial testing completed; no further action at this time.



February 17, 2016 (Rev 1)

Mr. Richard Cox
Indoor Air Quality Team Leader
Montgomery County Public Schools
850 Hungerford Drive
Rockville, MD 20850

Re: **Radon Testing Services**
KCI Job # 12146341.25

Location: William Tyler Page Elementary School
13400 Tamarack Road
Silver Spring, MD 20904

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the William Tyler Page Elementary School, located at 13400 Tamarack Road in Silver Spring, Maryland 20904 (subject site).

Scope of Services:

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Safety Board (NRSB) Radon Measurement Specialist (certification #14SS056) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from www.montgomerycountymd.gov/dep/air/radon or www.epa.gov/radon.

KCI visited the site on January 19, 2016 and deployed sixty-three (63) activated charcoal (AC) radon test kits. KCI deployed radon test kits in frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance. A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted six (6) test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on January 22, 2016 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc. is a NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936

Butler Bridge Road, Mills River, North Carolina.

Evaluation of Testing Conditions:

The operating condition that represents the greatest amount of significantly occupied time for this building is; heating active, with outdoor temperature averages $\leq 65^{\circ}$ F.

KCI concludes that the test period reasonably represents normal conditions when the building is significantly occupied. Clear characterization of the radon hazard is most likely to be observed under this normal operating condition. Based on the evaluation of test conditions, this test should reasonably characterize radon hazards.

KCI also conducted observations of field conditions which could affect the results of the test and compiled weather data for the testing period. KCI recorded observations of the following conditions in each room at the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

Results:

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥ 4.0 pCi/L	none	n/a
< 4.0 pCi/L	See Attachment B	

Notes:
D- Duplicate sample

All field blanks, office blank, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L. Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved. The Spike sample analysis results indicate the laboratory is operating within statistical control limits.

The sampling locations, field observations, and analytical results are listed on Table 1 (Attachment B). The laboratory analytical results are also attached (Attachment C). Laboratory results and exposure data for the spike samples are also included in Attachment C.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 316-7800.

Sincerely,



James M. Mouldale
Radon Measurement Specialist
KCI Technologies, Inc.

Attachments: A- Floor Plan with Test Locations
 B- Table 1-Radon Test Summary Spreadsheet
 C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Chek, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

QC- Quality Control

Radon Testing Results		
William Tyler Page Elementary School		
Test Period: 01/19/16-01/22/16		
Kit Number	Room / Area	Result
7717191	A103	< 0.3
7717186	A104	0.8
7717194	A105	1.2
7717163	A106	1.1
7717188	A107	1.6
7717181	A108	1.1
7717185	A109	0.9
7717189	A110	0.9
7717190	A111	2
7717171	A112	1
7717179	A113	3.2
7717177	A114	0.8
7717178	A115	1.4
7717183	A116	1.7
7717192	A117	0.8
7717193	A117A	< 0.3
7717160	AP	1.1
7717495	B101	< 0.3
7716775	C101	0.7
7717157	C102	1
7717156	C103	1.1
7717498	C104	2.1
7716774	CONF	1.3
7717175	D102	0.8
7717151	D103	1.6
7717158	D103	1
7717500	D103	1.1
7717195	E101	1
7717187	E103	0.5
7717152	F101	1.1
7717154	F102	1
7717176	F104	1
7717159	G101	1.2
7716773	GYM OFFICE	0.9
7717497	H201	< 0.3
7717166	H203	0.7
7717168	H206	0.6
7717167	H209	< 0.3
7717200	KIT	0.8
7716783	KITA	0.9
7716777	MC	1.1
7717491	MC	1.2
7716781	MC OFFICE	1.1
7717180	ML 969	< 0.3
7717174	ML918	< 0.3
7717196	MPR	1

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
William Tyler Page Elementary School		
Test Period: 01/19/16-01/22/16		
Kit Number	Room / Area	Result
7717197	MPR	1
7717198	MPR	1.3
7717496	OFF	1
7716778	OFFICE	1.3
7717161	PRI	1.2
7717165	WR	1.9

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
William Tyler Page Elementary Schoo		
Test Period: 01/19/16-01/22/16		
Kit Number	QC Type	Result
7717184	D (A109)	1.2
7717182	D (A113)	3.2
7717162	D (C104)	1.3
7716772	D (CONF)	1.3
7717153	D (F102)	1
7717199	D (KIT)	1.1
7717164	D (WR)	1.6
7717155	FB (A106)	< 0.3
7716779	FB (E101)	< 0.3
7717170	FB (H209)	< 0.3
7717499	OB (0)	< 0.3

Table Note:

* Missing or Compromised Sample

ATTACHMENT C

Laboratory Analytical Results

February 11, 2016 **LABORATORY ANALYSIS REPORT** **

Radon test result report for:
**WILLIAM TYLER PAGE ELEMENTARY SCHOOL
 MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7717499	0	2016-01-19 @ 6:00 pm	2016-01-22 @ 11:00 am	< 0.3	2016-01-27
7717191	A103	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	< 0.3	2016-01-27
7717186	A104	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	0.8 ± 0.3	2016-01-26
7717194	A105	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.2 ± 0.4	2016-01-26
7717155	A106	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-26
7717163	A106	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.1 ± 0.4	2016-01-26
7717188	A107	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	1.6 ± 0.4	2016-01-27
7717181	A108	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	1.1 ± 0.4	2016-01-27
7717185	A109	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	0.9 ± 0.3	2016-01-26
7717184	A109	2016-01-19 @ 2:00 pm	2016-01-22 @ 10:00 am	1.2 ± 0.4	2016-01-27
7717189	A110	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	0.9 ± 0.4	2016-01-27
7717190	A111	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	2.0 ± 0.4	2016-01-27
7717171	A112	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.4	2016-01-27
7717182	A113	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	3.2 ± 0.5	2016-01-26
7717179	A113	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	3.2 ± 0.5	2016-01-27
7717177	A114	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	0.8 ± 0.3	2016-01-26
7717178	A115	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.4 ± 0.4	2016-01-27
7717183	A116	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.7 ± 0.4	2016-01-27
7717192	A117	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	0.8 ± 0.3	2016-01-26
7717193	A117A	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	< 0.3	2016-01-27
7717160	AP	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.1 ± 0.3	2016-01-26
7717495	B101	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-27
7716775	C101	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	0.7 ± 0.3	2016-01-27
7717157	C102	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.4	2016-01-27
7717156	C103	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.1 ± 0.4	2016-01-27
7717162	C104	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.3 ± 0.4	2016-01-26
7717498	C104	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	2.1 ± 0.4	2016-01-27
7716772	CONF	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.3 ± 0.4	2016-01-26
7716774	CONF	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.3 ± 0.4	2016-01-26
7717175	D102	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	0.8 ± 0.3	2016-01-27
7717500	D103	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.1 ± 0.3	2016-01-26
7717151	D103	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.6 ± 0.4	2016-01-27
7717158	D103	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.4	2016-01-27
7716779	E101	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-27
7717195	E101	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.4	2016-01-27
7717187	E103	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	0.5 ± 0.3	2016-01-27
7717152	F101	2016-01-19 @ 4:00 pm	2016-01-22 @ 9:00 am	1.1 ± 0.4	2016-01-27

February 11, 2016
**LABORATORY ANALYSIS
REPORT ****

Radon test result report for:
**WILLIAM TYLER PAGE ELEMENTARY SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7717154	F102	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.3	2016-01-26
7717153	F102	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.4	2016-01-27
7717176	F104	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.3	2016-01-26
7717159	G101	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.2 ± 0.4	2016-01-26
7716773	GYM OFFICE	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	0.9 ± 0.3	2016-01-26
7717497	H201	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-26
7717166	H203	2016-01-19 @ 6:00 pm	2016-01-22 @ 10:00 am	0.7 ± 0.3	2016-01-27
7717168	H206	2016-01-19 @ 6:00 pm	2016-01-22 @ 10:00 am	0.6 ± 0.3	2016-01-26
7717167	H209	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-26
7717170	H209	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	< 0.3	2016-01-26
7717200	KIT	2016-01-19 @ 4:00 pm	2016-01-22 @ 9:00 am	0.8 ± 0.3	2016-01-26
7717199	KIT	2016-01-19 @ 4:00 pm	2016-01-22 @ 9:00 am	1.1 ± 0.4	2016-01-27
7716783	KITA	2016-01-19 @ 4:00 pm	2016-01-22 @ 9:00 am	0.9 ± 0.3	2016-01-26
7716781	MC off	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.1 ± 0.3	2016-01-26
7717491	MC	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.2 ± 0.3	2016-01-26
7716777	MC	2016-01-19 @ 4:00 pm	2016-01-22 @ 10:00 am	1.1 ± 0.3	2016-01-27
7717196	MPR	2016-01-19 @ 3:00 pm	2016-01-22 @ 9:00 am	1.0 ± 0.3	2016-01-26
7717197	MPR	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.3	2016-01-26
7717198	MPR	2016-01-19 @ 3:00 pm	2016-01-22 @ 10:00 am	1.3 ± 0.3	2016-01-26
7717496	OFF	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.0 ± 0.3	2016-01-26
7716778	OFFIC	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.3 ± 0.3	2016-01-26
7717161	E PRI	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.2 ± 0.3	2016-01-26
7717165	WR	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.9 ± 0.4	2016-01-26
7717164	WR	2016-01-19 @ 5:00 pm	2016-01-22 @ 10:00 am	1.6 ± 0.4	2016-01-27

February 11, 2016
**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**WILLIAM TYLER PAGE ELEMENTARY SCHOOL
PORTABLE**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7717180	ML 969	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	< 0.3	2016-01-27
7717174	ML918	2016-01-19 @ 2:00 pm	2016-01-22 @ 9:00 am	< 0.3	2016-01-26

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

February 2, 2016
LABORATORY ANALYSIS REPORT

Radon test result report for:
MCPS PHASE 5 & 6 TRANSIT BLANKS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7722194	1	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718494	10	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718475	11	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718495	12	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718496	13	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718497	14	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718498	15	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718499	16	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718500	17	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718296	18	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718295	19	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722195	2	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716789	20	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716785	21	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-26
7716791	22	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716786	23	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716793	24	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718274	25	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716792	26	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718294	27	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718293	28	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718292	29	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722197	3	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718290	30	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722198	4	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722199	5	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722211	6	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718491	7	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718476	8	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-26
7718479	9	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27

February
15,
2016

****LABORATORY ANALYSIS
REPORT ****

Spike Sample Laboratory Results

Radon test result report for:
MCPS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7718273	101A	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.5 ± 0.6	2016-02-04
7718281	102B	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.4 ± 0.6	2016-02-04
7718282	103C	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.3 ± 0.6	2016-02-04
7718288	104D	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.7 ± 0.6	2016-02-04
7718289	105E	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.6 ± 0.6	2016-02-04
7718291	106F	2016-01-30 @ 9:00 am	2016-02-01 @ 9:00 am	6.5 ± 0.6	2016-02-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Note: Spike samples are test canisters that are deliberately exposed to a controlled high level of radon in a laboratory. They provide a quality control measure in the testing process and do NOT reflect radon levels in the building being tested.

EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCF Technologies Inc. Job Number 173704

NOMINAL Conditions: Radon Conc 5.9 pCi/L Rel. Hum 45.9 % Temp. 79.0 F

Date Start: 1/30/16 Date Stop: 2/1/16 Date Start: _____ Date Stop: _____

Time Start: 0926 Time Stop: 0926 Time Start: _____ Time Stop: _____

Device No.'s: (6) Char. Bags - Device No.'s: _____

7718281, 7718282, 7718291, _____

7718288, 7718289, 7718273 _____

ε3 Left

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

**Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)
Background = 7 μR/h Elevation = 820 ft**



Chain of Custody

Project Name: MCPS Radon Phase VI

Name of Schools:

- | | | |
|--------------------------|------------------------------|---------------------------|
| 1. Francis Scott Key MS | 12. Little Bennett ES | 23. Rolling Terrace ES |
| 2. Gaithersburg ES | 13. Loiderman MS | 24. Roscoe Nix ES |
| 3. Gaithersburg MS | 14. Longview ES | 25. Sally K. Ride ES |
| 4. Galway ES | 15. Meadow Hall ES | 26. Spark Matsunaga ES |
| 5. Great Seneca Creek ES | 16. Neelsville MS | 27. Tacoma Park ES |
| 6. Harmony Hills ES | 17. New Hampshire Estates ES | 28. Thomas Pyle MS |
| 7. John Poole MS | 18. North Bethesda MS | 29. Wayside ES |
| 8. Judith A. Resnik ES | 19. Northwest HS | 30. Westbrook ES (retest) |
| 9. Kemp Mill ES | 20. Pine Crest ES | 31. Westland MS (retest) |
| 10. Kingsview MS | 21. Radnor Center | 32. William B. Gibbs ES |
| 11. Lakelands Park MS | 22. Ritchie Park ES | 33. William Tyler Page ES |

	Date	Initials
Radon Test Kits Deployed	1/19/16	JM
Radon Test Kits Sampled	1/22/16	JM
Radon Test Kits Shipped to Lab*	1/22/16	JM
Radon Test Kits Received by Lab*	1/26/16	JM

*All samples sent to Air Check, Inc., 1936 Butler Bridge Road, Mills River, NC 28758